

Robert P. Astorino
County Executive

Sherlita Amler, M.D.
Commissioner of Health

September 11, 2012

Village of Croton-on-Hudson
1 Van Wyck Street
Croton-on-Hudson, NY 10520
Attn: Abraham J. Zambrano, Village Manager

RE: Notice of Copper Action Level Exceedance
Croton-on-Hudson Public Water Supply
Croton-on-Hudson (V)
PWS ID: 5903425

Dear Mr. Zambrano:

A review of the first draw lead and copper tap sample test results submitted for the above referenced public water supply for the 2012 monitoring period revealed that the 90th percent copper level was 1.57 mg/L, which exceeds the Copper Action Level of 1.3 mg/l in violation of Part 5, Subpart 5-1, Section 5-1.41 (b) of the New York State Sanitary Code (NYSSC).

Due to the Copper Action Level exceedance, you are required to recommend a corrosion control treatment that will result in optimal corrosion treatment, within six months in accordance with Part 5, Subpart 5-1, Section 5-1.46 (b) of the NYSSC.

In addition, the public water supply must resume lead and copper monitoring at the standard number of sampling sites every six months beginning with the January 01 to June 30, 2013 monitoring period. Also, the public water supply shall commence Water Quality Parameter Monitoring beginning with the January 01 to June 30, 2013 monitoring period in accordance with Part 5, Subpart 5-1, Section 5-1.43 of the NYSSC.

Further, the public water supply must conduct source water monitoring for lead and copper within six months of the Copper Action Level exceedance in accordance with Part 5, Subpart 5-1, Section 5-1.47 of the NYSSC.

If you have any questions, please contact the undersigned at 914-864-7296.

Very truly yours,



Delroy Taylor, P.E.
Associate Engineer
Bureau of Environmental Quality

DT:jpg

cc: Dan O'Connor, P.E., Village Engineer
Thomas Brann, Designated Operator
Anna Stamm, P.E. - NYSDOH
File

